





KDK Company, Division of PES and Panasonic Ecology Systems (Thailand) Co., Ltd. certify that the window mount series models shown herein are licensed to bear the AMCA seal. The ratings shown are based on the tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program.

## Specification

Model	Valtaga	Frequency	CFM/SONE at static pressure(ps-inches of H <sub>2</sub> O)					RPM	Motto*	Watts**
	voltage		inches of H <sub>2</sub> O	0	0.05	0.1	0.15		vvalls	vvaus
15WHCT	220V	60Hz	CFM	127	94	63	31	2440	14.6	13
			Sones	3.0	3.6	3.5	3.9			
		50Hz	CFM	127	95	68	50	2537	16	15
	240V		Sones	2.3	2.7	3.5	2.8			

Performance certified is for installation type A: Free inlet, Free outlet.

Performance ratings include the effects of a shutter.

The speed (RPM) and Watts rating shown are at the static pressure of 0 inch of H<sub>2</sub>O.

The sound ratings shown are loudness values in fan sones at 5 ft. (1.5m) in a hemispherical free field calculated per AMCA International Standard 301. Values shown are for installation type A: Free inlet hemispherical sone levels.

\* the Watts rating is only for AMCA test method and it is at the static pressure of 0 inch of  $H_2O$ .

\*\* the Watts rating is only for IEC test method and the AMCA Certified Ratings Seal does not apply to IEC test method watts.

F	Product	Model						
Window Mo	unt Ventilating	15WHCT (AMCA)						
Make Date	2015.01.06	Scale	Drawing No.					
Modification Date			Modification No.					
KDK Company, Division of PES								